ADDENDUM

Oconee Joint Regional Sewer Authority Work Plan (2022) Corrective Repairs WKD Project Number 20230009.00.GV

ADDENDUM NUMBER 02

06-27-2023

BID DATE: July 18, 2023, until 2:00 p.m.

TO ALL BIDDERS:

This Addendum forms a part of the Contract Documents and modifies the Bidding Documents dated **June 2023**, and all previous Addenda.

Acknowledge receipt of this Addendum in the space provided in the Bid Form. Failure to do so may disqualify the Bidder.

Below are changes, additions, and/or clarifications to the bid documents for this project.

Specifications

Item 1: Summary 01 11 00 -1

Remove Section 1.4 C. Items furnished by Owner for installation by Contractor.

Clarifications

<u>Item 2</u>: Contractor shall furnish material for repairs. Owner will not provide material for repairs.

<u>Item 3:</u> CCTV video inspections for the respective repairs with defects to be corrected can be provided. Request must be made to OJRSA.

<u>Item 4:</u> Bypass pumping is included in the repair cost except where flows are anticipated to be above 2.0 MGD. Repairs with flows higher than 2.0 MGD is indicated on the Bid Form.

<u>Item 5:</u> Bidder will need to provide cost deductions for a owner provided bypass services. The cost deductions are on the bid form as Deductive Alternatives for the Base Bid and each Additive Alternative.

<u>Item 6</u>: Contractor is responsible for all necessary permits and coordination with appropriate agencies including, but not limited to, SCDOT and SCDHEC, as required.

<u>Item 7:</u> Contractor is responsible for being familiar with the project area, entrances and terrain prior to bidding. Special emphasis noted the clearance and crossing of the SCDOT Bridge on C4.

<u>Item 8:</u> Special emphasis for Bidder to review Section 00 80 00 Special Provisions.

<u>Item 9:</u> Contractor is responsible for being familiar with the project area, entrances and terrain prior to bidding. Special emphasis noted the clearance and crossing of the SCDOT Bridge on C4.

Receipt of this addendum must be acknowledged on Page 00 41 43-1 of your Bid Form.

Sincerely,

W. K. Dickson & Co., Inc.

SEAL

SC Certificate of Authorization No. C00177

Joseph F. Swaim, P.E. Project Manager

JFS/aeh

Enclosures:

June 22, 2023 Pre-Bid Attendance Sign-In Sheet

Oconee Joint Regional Sewer Authority TO #09 Work Plan (2022) Corrective Repairs WKD Project Number: 20230009.00.GV



Oconee Joint Regional Sewer Authority

623 Return Church Road Seneca, South Carolina 29678 Phone (864) 972-3900 www.ojrsa.org

Meeting Host(s): OJRSA & WK DISCKSON Meeting: Consent Order Work Plan Corrective Repairs (RFB Project #2024-02) June 22, 2023 Date: Time: 09:00 Location: OJRSA **SIGNATURE** NAME (Print) ORGANIZATION/COMPANY **PHONE EMAIL** Iswaim@wkdickson.con Joseph Swain 843-666-2902 WK Dickson OJRSA 864-973-1016 Kyle. Lindson QOTRIA.055 864-710-6109