



Manhole Vacuum Test

SC DHEC Project Name: _____

Date: _____ SC DHEC Permit Number: _____

Contractor: _____

Engineering Firm: _____

Note: Test Time shall be per ASTM C1244 for the vacuum pressure to drop from 10 inHg to 9 inHg. Test passes if Pressure Drop is less than 1 inHg for Test Time.

Manhole Number	Diameter (ft.)	Rim Elevation (MSL)	Invert Out Elevation (MSL)	Depth (ft.)	Test time (sec.)	Start Test Pressure (inHg)	Pressure Drop (inHg)	Pass/Fail

Contractor Representative: _____ Date: _____

Engineer Representative: _____ Date: _____

OJRSA Representative: _____ Date: _____